


NAME

Fluids-ID

Quiz 7. The *pump-turbine* system in the figure draws water from the upper reservoir in the daytime to produce power for a city. At night, it pumps water from lower to upper reservoirs to restore the situation. For a design flow rate of 15,000 gal/min (or 33.4 ft³/s) in either direction, the frictional head loss is 17 ft. Estimate the power in horse power (a) extracted by the turbine and (b) delivered by the pump. (Note: $\dot{W}_t = \gamma Q h_t$ and $\dot{W}_p = \gamma Q h_p$; $\gamma = 62.4 \text{ lbf/ft}^3$; 1 hp = 550 ft·lbf/s)



- Energy equation:

$$\frac{p_1}{\gamma} + \frac{V_1^2}{2g} + z_1 + h_p = \frac{p_2}{\gamma} + \frac{V_2^2}{2g} + z_2 + h_t + h_L$$

Solution:

(a) For turbine operation, take the upper reservoir surface as the point “1” (i.e., upstream) in the energy equation, and with $p_1 = p_2 = 0$, $V_1 \approx V_2 \approx 0$, and $h_p = 0$,

$$0 + 0 + z_1 + 0 = 0 + 0 + z_2 + h_t + h_L$$

$$\therefore h_t = z_1 - z_2 - h_L = 150 \text{ ft} - 25 \text{ ft} - 17 \text{ ft} = 108 \text{ ft} \quad (+3 \text{ points})$$

Thus,

$$\dot{W}_t = \gamma Q h_t = \left(62.4 \frac{\text{lbf}}{\text{ft}^3} \right) \left(33.4 \frac{\text{ft}^3}{\text{s}} \right) (108 \text{ ft}) = 225,000 \frac{\text{lbf} \cdot \text{ft}}{\text{s}} = \mathbf{410 \text{ hp}} \quad (+2 \text{ points})$$

(b) For pump operation, take the lower reservoir surface as the point “1” (i.e., upstream) in the energy equation, and with $p_1 = p_2 = 0$, $V_1 \approx V_2 \approx 0$, and $h_t = 0$,

$$0 + 0 + z_1 + h_p = 0 + 0 + z_2 + h_L$$

$$\therefore h_p = z_2 - z_1 + h_L = 150 \text{ ft} - 25 \text{ ft} + 17 \text{ ft} = 142 \text{ ft} \quad (+3 \text{ points})$$

Thus,

$$\dot{W}_p = \gamma Q h_p = \left(62.4 \frac{\text{lbf}}{\text{ft}^3} \right) \left(33.4 \frac{\text{ft}^3}{\text{s}} \right) (142 \text{ ft}) = 296,000 \frac{\text{lbf} \cdot \text{ft}}{\text{s}} = \mathbf{540 \text{ hp}} \quad (+2 \text{ points})$$